Thin joint mortars

(Withdrawn - January 2024)

The Technical Guidance Notes are produced by NHBC as guidance solely for our builder customers as to how to interpret the technical requirements in relation to the warranty cover provided by NHBC under its Buildmark, Buildmark Choice, Buildmark Link, Buildmark Solo, Buildmark Connect or any similar product from time to time. It has not been created or intended for distribution or use outside of that purpose. The information contained in this Technical Guidance Note does not constitute advice and is not to be relied upon by any third party. Nothing in this Technical Guidance Note is intended to, nor should it be taken to, create any legal or contractual relationship. Any third party who chooses to rely upon the information contained in the Technical Guidance Notes shall do so entirely at their own risk and NHBC accepts no duty of care or liability, however caused, in connection with its use or reliance by any third party.

Question

Can thin joint mortar be used in temperatures below 2°C?

Considerations

- NHBC Standards Chapter 3.2 'Cold weather working' Clause 3.2.5 'masonry' says 'when laying masonry in cold weather and temperatures are below, or likely to fall below 2°C, masonry should not be laid'.
- Some thin joint masonry mortars have manufacturer's guidance stating they can be used down to as low as 0°C.

Answer

Thin joint mortars that can be shown to have been successfully tested for use down to 0°C are acceptable when the temperature is 0°C and rising.

The mortar should be used strictly in accordance with the manufacturer's instructions and Chapter 3.2 'Cold weather working'.



NHBC, NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Bucks MK5 8FP Tel: 0344 633 1000 Web: nhbc.co.uk