

Risers to private stairs – thick floor coverings

(Withdrawn – January 2024)

The Technical Guidance Notes are produced by NHBC as guidance solely for our builder customers as to how to interpret the technical requirements in relation to the warranty cover provided by NHBC under its Buildmark, Buildmark Choice, Buildmark Link, Buildmark Solo, Buildmark Connect or any similar product from time to time. It has not been created or intended for distribution or use outside of that purpose. The information contained in this Technical Guidance Note does not constitute advice and is not to be relied upon by any third party. Nothing in this Technical Guidance Note is intended to, nor should it be taken to, create any legal or contractual relationship. Any third party who chooses to rely upon the information contained in the Technical Guidance Notes shall do so entirely at their own risk and NHBC accepts no duty of care or liability, however caused, in connection with its use or reliance by any third party.

Question

Where thick floor coverings such as laminated flooring or tiles are laid in a hallway, can a tolerance for the floor finish be allowed in the height of first stair riser?

Considerations

- Unequal risers can create a trip hazard.
- Approved Document K (England & Wales), Scottish Building Standards Technical Handbook Domestic Section 4.3 and Building Regulations (Northern Ireland) Technical Handbook H, require all risers to be equal.
- NHBC Standards clauses 6.6 – D5(b) and 6.6 – S2(e) requires that all steps should have the same rise and that thickness of screeds and floor finishes should be taken into account.

Answer

The height of the first riser should be the same as the risers in the rest of the flight. The height should be measured from the structural floor finish i.e. the top of the cement screed or timber floor decking.

Where floor finishes of up to 12mm thick are installed, their effect on the height of the first riser may be ignored. However, where the builder installs a floor finish with a thickness greater than 12mm (e.g. thick laminate flooring or thick tiles) the stairs should be installed so that the height of the first riser, measured from the top of the floor finish, is equal to the risers in the rest of the flight.



NHBC, NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Bucks MK5 8FP
Tel: 0344 633 1000 Web: nhbc.co.uk

National House-Building Council (NHBC) is authorised by the Prudential Regulation Authority and regulated by the Financial Conduct Authority and the Prudential Regulation Authority for carrying on insurance business and insurance distribution activities.

NHBC is registered in England and Wales under company number 00320784. NHBC's registered address is NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Buckinghamshire, MK5 8FP. Note that only certain parts of our products and services are within the scope of UK financial services regulations. For more information on our products and services, please see our website nhbc.co.uk or your NHBC product documentation.