

# Door ironmongery – student accommodation

(November 2024) (Second issue – supersedes March 2013)

The Technical Guidance Notes are produced by NHBC as guidance solely for our builder customers as to how to interpret the technical requirements in relation to the warranty cover provided by NHBC under its Buildmark, Buildmark Choice, Buildmark Link, Buildmark Solo, Buildmark Connect or any similar product from time to time. It has not been created or intended for distribution or use outside of that purpose. The information contained in this Technical Guidance Note does not constitute advice and is not to be relied upon by any third party. Nothing in this Technical Guidance Note is intended to, nor should it be taken to, create any legal or contractual relationship. Any third party who chooses to rely upon the information contained in the Technical Guidance Notes shall do so entirely at their own risk and NHBC accepts no duty of care or liability, however caused, in connection with its use or reliance by any third party.

## Question

Are opening limitation devices, door viewers and keyless egress locks required on doors to student cluster accommodation?

## Considerations

- NHBC Standards clause 6.7 – D4 (b) requires an opening limitation device to main entrance doors.
- NHBC Standards clause 6.7 – D4 (c) requires a view outside the main entrance door.
- NHBC Standards clause 6.7 – D4 (a) requires a door opening on to a communal access to have keyless egress.

## Answer

Student cluster accommodation consist of a small number of individual student bedrooms with a shared lounge/ kitchen/dining area. All rooms open off a private corridor which itself is accessed via a door off a communal access.

The door between the private corridor and the communal access is considered to be the main entrance door to each cluster. The door to each student bedroom is considered to be an internal door.

The main entrance door to each cluster should be fitted with a door viewer or vision panel to give a view on to the communal access. The door should be fitted with a lock which is openable on the inside by use of a handle or thumb turn and a key from the outside i.e. from the communal access. Unlike an entrance door to ordinary flatted accommodation, which opens on to a communal area, the door lock to student cluster accommodation should be self-latching to maintain security.

A door limitation device should not be fitted to the main entrance door as it could hinder or prevent access by the individual students living in the cluster.

For privacy purposes locks are normally fitted to each bedroom door. Such locks should hold the door closed on a latch and provide keyless egress at all times. A mortice sash lock with lever furniture and thumb turn cylinder would satisfy these requirements. Provision of a door viewer and door limitation device is optional.



**NHBC, NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Bucks MK5 8FP**  
**Tel: 0344 633 1000 Web: nhbc.co.uk**

National House-Building Council (NHBC) is authorised by the Prudential Regulation Authority and regulated by the Financial Conduct Authority and the Prudential Regulation Authority for carrying on insurance business and insurance distribution activities.

NHBC is registered in England and Wales under company number 00320784. NHBC's registered address is NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Buckinghamshire, MK5 8FP. Note that only certain parts of our products and services are within the scope of UK financial services regulations. For more information on our products and services, please see our website [nhbc.co.uk](http://nhbc.co.uk) or your NHBC product documentation.