



Consumer unit – labelling

(Withdrawn – January 2024)

The Technical Guidance Notes are produced by NHBC as guidance solely for our builder customers as to how to interpret the technical requirements in relation to the warranty cover provided by NHBC under its Buildmark, Buildmark Choice, Buildmark Link, Buildmark Solo, Buildmark Connect or any similar product from time to time. It has not been created or intended for distribution or use outside of that purpose. The information contained in this Technical Guidance Note does not constitute advice and is not to be relied upon by any third party. Nothing in this Technical Guidance Note is intended to, nor should it be taken to, create any legal or contractual relationship. Any third party who chooses to rely upon the information contained in the Technical Guidance Notes shall do so entirely at their own risk and NHBC accepts no duty of care or liability, however caused, in connection with its use or reliance by any third party.

Question

What labels/notices should be provided on consumer units?

Considerations

- BS 7671 'Requirements for Electrical Installations' clause 514-8 refers to the identification of each protective device, e.g. fuse or circuit breaker.
- BS 7671 clause 514-12 deals with notices for periodic inspection and testing. These notices should be fixed in a permanent position at or near the origin of every installation. The most convenient location for these notices is usually on the consumer unit.
- Where an installation incorporates a Residual Current Device (RCD) a notice should be provided advising the homeowner on when and how to carry out periodic testing of the device.

Answer

The following labels/notices should be provided in or close to the consumer unit:

1. **Each fuse or circuit breaker should be labelled so that the circuit protected by the device can be easily identified.**
2. **A notice saying:**

IMPORTANT

This installation should be periodically inspected and tested and a report on its condition obtained, as prescribed in the IEE Wiring Regulations BS 7671 Requirements for Electrical Installations.

Date of last inspection

Recommended date of next inspection

3. **Where RCDs are provided, a notice saying:**

This installation, or part of it, is protected by a device which automatically switches the supply if an earth fault develops. Test quarterly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice.

Notices should be of durable material and indelibly marked.

There is no requirement for the name of the electrical contractor to be shown on the label/notice. The name and signature of the designer, contractor and the 'competent person' who carried out the test will be on the Electrical Test Certificate.



NHBC, NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Bucks MK5 8FP
Tel: 0344 633 1000 Web: nhbc.co.uk

National House-Building Council (NHBC) is authorised by the Prudential Regulation Authority and regulated by the Financial Conduct Authority and the Prudential Regulation Authority for carrying on insurance business and insurance distribution activities.

NHBC is registered in England and Wales under company number 00320784. NHBC's registered address is NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Buckinghamshire, MK5 8FP. Note that only certain parts of our products and services are within the scope of UK financial services regulations. For more information on our products and services, please see our website nhbc.co.uk or your NHBC product documentation.