Bracing of mono-pitch roof trusses

(May 2024) (Second issue - supersedes December 2008)

The Technical Guidance Notes are produced by NHBC as guidance solely for our builder customers as to how to interpret the technical requirements in relation to the warranty cover provided by NHBC under its Buildmark, Buildmark Choice, Buildmark Link, Buildmark Solo, Buildmark Connect or any similar product from time to time. It has not been created or intended for distribution or use outside of that purpose. The information contained in this Technical Guidance Note does not constitute advice and is not to be relied upon by any third party. Nothing in this Technical Guidance Note is intended to, nor should it be taken to, create any legal or contractual relationship. Any third party who chooses to rely upon the information contained in the Technical Guidance Notes shall do so entirely at their own risk and NHBC accepts no duty of care or liability, however caused, in connection with its use or reliance by any third party.

Question

Do mono-pitch trussed rafters, bearing in the web of a steel joist, need to have solid blocking like floor joists, or is the longitudinal bracing, nailed on top of the ceiling joists sufficient?

Considerations

Lateral restraint is needed to the heel of the trusses for structural support and location purposes.

Answer

The longitudinal bracing at the intersection of the ceiling member and the vertical end member of the truss is sufficient. Solid blocking is not required in addition.



NHBC, NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Bucks MK5 8FP Tel: 0344 633 1000 Web: nhbc.co.uk