

Field drainage systems to septic tanks and small private sewage treatment plants

(August 2024) (Third issue – supersedes June 2022)

The Technical Guidance Notes are produced by NHBC as guidance solely for our builder customers as to how to interpret the technical requirements in relation to the warranty cover provided by NHBC under its Buildmark, Buildmark Choice, Buildmark Link, Buildmark Solo, Buildmark Connect or any similar product from time to time. It has not been created or intended for distribution or use outside of that purpose. The information contained in this Technical Guidance Note does not constitute advice and is not to be relied upon by any third party. Nothing in this Technical Guidance Note is intended to, nor should it be taken to, create any legal or contractual relationship. Any third party who chooses to rely upon the information contained in the Technical Guidance Notes shall do so entirely at their own risk and NHBC accepts no duty of care or liability, however caused, in connection with its use or reliance by any third party.

Question

Are coiled flexible internally ribbed plastic land drains suitable for use in the field drainage from a septic tank or a small private sewage treatment plant?

Considerations

- NHBC Standards chapter 5.3.10 refers to field drains for the disposal of the discharge from septic tanks.
- Small solid particles in the discharge from septic tanks and treatment plants can over time accumulate on ribbed pipe surfaces and cause blockages.
- Pipes should be laid to a uniform gradient. Dips in flexible pipes can cause settlement of solid particles and potential blockages.
- Manufacturers of septic tanks and small treatment plants do not recommend the use of flexible plastic land drains to form the drainage field from their units.

Answer

The field drain from a septic tank or small private sewage treatment plant should be formed with rigid perforated pipes (rigid plastic or clay) having a smooth inner surface. Pipes should be laid to uniform falls.

Coiled ribbed plastic land drains are not suitable for this purpose.



NHBC, NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Bucks MK5 8FP
Tel: 0344 633 1000 Web: nhbc.co.uk

National House-Building Council (NHBC) is authorised by the Prudential Regulation Authority and regulated by the Financial Conduct Authority and the Prudential Regulation Authority for carrying on insurance business and insurance distribution activities.

NHBC is registered in England and Wales under company number 00320784. NHBC's registered address is NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Buckinghamshire, MK5 8FP. Note that only certain parts of our products and services are within the scope of UK financial services regulations. For more information on our products and services, please see our website [nhbc.co.uk](https://www.nhbc.co.uk) or your NHBC product documentation.