Underground drainage - pipe cross-overs

(August 2024) (Third issue - supersedes June 2021)

The Technical Guidance Notes are produced by NHBC as guidance solely for our builder customers as to how to interpret the technical requirements in relation to the warranty cover provided by NHBC under its Buildmark, Buildmark Choice, Buildmark Link, Buildmark Solo, Buildmark Connect or any similar product from time to time. It has not been created or intended for distribution or use outside of that purpose. The information contained in this Technical Guidance Note does not constitute advice and is not to be relied upon by any third party. Nothing in this Technical Guidance Note is intended to, nor should it be taken to, create any legal or contractual relationship. Any third party who chooses to rely upon the information contained in the Technical Guidance Notes shall do so entirely at their own risk and NHBC accepts no duty of care or liability, however caused, in connection with its use or reliance by any third party.

Question

Where drainage pipes cross over one another within unadopted areas, what clearance should be provided between the pipes at the point where they cross?

Considerations

- NHBC Standards clause 5.3.15 makes reference to general pipe bedding requirements.
- Drainage pipes should be bedded and backfilled with suitable material to provide the pipes with full support and avoid point loads on the pipes.

Answer

Drainage pipes should not make contact with each other as this can lead to a concentrated load where the pipes touch, which can cause damage to the pipes.

To avoid the risk of concentrated loads drainage pipes should be surrounded in a minimum 100mm pea shingle and kept 100mm apart where they cross each other.

Where pipe gradients cannot be adjusted to provide a 100mm clearance, at the point of cross-over, a minimum 50mm clearance may be accepted.



NHBC, NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Bucks MK5 8FP Tel: 0344 633 1000 Web: nhbc.co.uk