Firestopping to garage walls

(Withdrawn - January 2024)

The Technical Guidance Notes are produced by NHBC as guidance solely for our builder customers as to how to interpret the technical requirements in relation to the warranty cover provided by NHBC under its Buildmark, Buildmark Choice, Buildmark Link, Buildmark Solo, Buildmark Connect or any similar product from time to time. It has not been created or intended for distribution or use outside of that purpose. The information contained in this Technical Guidance Note does not constitute advice and is not to be relied upon by any third party. Nothing in this Technical Guidance Note is intended to, nor should it be taken to, create any legal or contractual relationship. Any third party who chooses to rely upon the information contained in the Technical Guidance Notes shall do so entirely at their own risk and NHBC accepts no duty of care or liability, however caused, in connection with its use or reliance by any third party.

Question

Should the wall between an integral garage and the house be built up between the floor joists to the underside of the floor decking?

Considerations

- 30 minutes' fire separation to rooms above and around the garage should be provided.
- There should be no pathway for fire through the construction.

Answer

The wall does not need to be built up to the underside of the floor decking where the ceiling construction provides the full 30 minutes' fire resistance on its own. Otherwise, the wall should be built up to the underside of the floor decking with a non-combustible material such as glass fibre fitted between the top of the wall and the underside of the decking.

- * Some typical ceiling constructions that provide the full 30 minutes' fire resistance are as follows:
- Two layers of 12.5mm plasterboard with staggered joints, taped and filled and 150mm glass fibre laid between joists. (Ensure all joints in second layer are located over a joist or nogging).
- One layer of 12.5mm fire resistant plasterboard with joints taped and filled and 150mm glass fibre laid between
 joists. (Ensure all joints are located over a joist or nogging).

Other constructions may be acceptable. If in doubt, please seek advice from the NHBC Building Surveyor.



NHBC, NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Bucks MK5 8FP Tel: 0344 633 1000 Web: nhbc.co.uk