

Timber stud partitions

(Withdrawn – January 2023)

The Technical Guidance Notes are produced by NHBC as guidance solely for our builder customers as to how to interpret the technical requirements in relation to the warranty cover provided by NHBC under its Buildmark, Buildmark Choice, Buildmark Link, Buildmark Solo, Buildmark Connect or any similar product from time to time. It has not been created or intended for distribution or use outside of that purpose. The information contained in this Technical Guidance Note does not constitute advice and is not to be relied upon by any third party. Nothing in this Technical Guidance Note is intended to, nor should it be taken to, create any legal or contractual relationship. Any third party who chooses to rely upon the information contained in the Technical Guidance Notes shall do so entirely at their own risk and NHBC accepts no duty of care or liability, however caused, in connection with its use or reliance by any third party.

Question

Are intermediate noggings required in timber stud partitions?

Considerations

- NHBC Standards clause 6.3 – S4(b) refers to the minimum size for noggings when provided as part of a design for load-bearing stud partitions.
- NHBC Standards Appendix 8.2 – A refers to the provision of noggings when applying ceramic wall tiling on stud partitions.
- BS 8212 'Dry lining and partitioning using gypsum plasterboard' refers to the provision of noggings to all horizontal plasterboard edges in walls.
- Intermediate noggings increase the stiffness of a partition and help reduce twisting during drying out of the studs.
- Plasterboard manufacturers' recommendations do not require intermediate noggings for the fixing or support of plasterboard when fixed to vertical studs spaced at max. 600mm centres.

Answer

Unless required as part of the design of the stud partition intermediate noggings are not normally required. However, the provision of intermediate noggings is considered good practice as they improve the stiffness of the partition and reduce the risk of the timber studs twisting during the drying out period.



NHBC, NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Bucks MK5 8FP
Tel: 0344 633 1000 Web: nhbc.co.uk

National House-Building Council (NHBC) is authorised by the Prudential Regulation Authority and regulated by the Financial Conduct Authority and the Prudential Regulation Authority for carrying on insurance business and insurance distribution activities.

NHBC is registered in England and Wales under company number 00320784. NHBC's registered address is NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Buckinghamshire, MK5 8FP. Note that only certain parts of our products and services are within the scope of UK financial services regulations. For more information on our products and services, please see our website nhbc.co.uk or your NHBC product documentation.