Sealing around ends of engineered I-joists

(Withdrawn - January 2024)

The Technical Guidance Notes are produced by NHBC as guidance solely for our builder customers as to how to interpret the technical requirements in relation to the warranty cover provided by NHBC under its Buildmark, Buildmark Choice, Buildmark Link, Buildmark Solo, Buildmark Connect or any similar product from time to time. It has not been created or intended for distribution or use outside of that purpose. The information contained in this Technical Guidance Note does not constitute advice and is not to be relied upon by any third party. Nothing in this Technical Guidance Note is intended to, nor should it be taken to, create any legal or contractual relationship. Any third party who chooses to rely upon the information contained in the Technical Guidance Notes shall do so entirely at their own risk and NHBC accepts no duty of care or liability, however caused, in connection with its use or reliance by any third party.

Question

Where timber engineered I-joists are built into a wall, can foam be used to seal the gap between the sides of the joists and the masonry?

Considerations

- Joists should be fully built into the wall to avoid leaving gaps, which would affect the air tightness of the building
 and reduce thermal insulation and the fire resistance of the wall.
- The material used to fill the gap should not protrude into the cavity.
- The material used to fill the gap should be non-combustible.

Answer

Expanding foam fill should not be used for filling the gap between the joists and masonry.



NHBC, NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Bucks MK5 8FP Tel: 0344 633 1000 Web: nhbc.co.uk