## Pitched roofs – bedding verge undercloaks

(Withdrawn - January 2024)

The Technical Guidance Notes are produced by NHBC as guidance solely for our builder customers as to how to interpret the technical requirements in relation to the warranty cover provided by NHBC under its Buildmark, Buildmark Choice, Buildmark Link, Buildmark Solo, Buildmark Connect or any similar product from time to time. It has not been created or intended for distribution or use outside of that purpose. The information contained in this Technical Guidance Note does not constitute advice and is not to be relied upon by any third party. Nothing in this Technical Guidance Note is intended to, nor should it be taken to, create any legal or contractual relationship. Any third party who chooses to rely upon the information contained in the Technical Guidance Notes shall do so entirely at their own risk and NHBC accepts no duty of care or liability, however caused, in connection with its use or reliance by any third party.

## Question

Should the verge undercloak to a pitched roof be bedded on mortar where it passes over the masonry wall?

## **Considerations**

- NHBC Standards clause 7.2.19 refers to the bedding of undercloaks on to masonry walls.
- The bedding is needed to prevent rainwater penetration and neatly finish the joint between undercloak and top
  of masonry wall.

## **Answer**

The verge undercloak should be bedded on mortar where it passes over a masonry wall. Mastic pointing can also be acceptable, in place of the mortar bedding, provided a neat weatherproof joint can be achieved between the undercloak and masonry.



NHBC, NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Bucks MK5 8FP Tel: 0344 633 1000 Web: nhbc.co.uk