

# Extract fans – air leakage

(Withdrawn – January 2024)

The Technical Guidance Notes are produced by NHBC as guidance solely for our builder customers as to how to interpret the technical requirements in relation to the warranty cover provided by NHBC under its Buildmark, Buildmark Choice, Buildmark Link, Buildmark Solo, Buildmark Connect or any similar product from time to time. It has not been created or intended for distribution or use outside of that purpose. The information contained in this Technical Guidance Note does not constitute advice and is not to be relied upon by any third party. Nothing in this Technical Guidance Note is intended to, nor should it be taken to, create any legal or contractual relationship. Any third party who chooses to rely upon the information contained in the Technical Guidance Notes shall do so entirely at their own risk and NHBC accepts no duty of care or liability, however caused, in connection with its use or reliance by any third party.

## Question

Do extract fans/cooker hoods or their ducting require non-return shutters to reduce air leakage?

## Title

## Considerations

- An unrestricted extract duct through the wall can create a path for unwanted airflow between the inside and outside of a dwelling.
- Approved Document L1 (England & Wales) requires unwanted air leakage to be reduced.
- Robust Details gives guidance on ways to comply with Approved Document L1 but this does not make reference to air leakage through fans and cooker hoods.

## Answer

To comply with Approved Document L1 (England & Wales) it is not necessary to provide non-return shutters on extract fans/cooker hoods or their ducting.



**NHBC, NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Bucks MK5 8FP**  
**Tel: 0344 633 1000 Web: nhbc.co.uk**

National House-Building Council (NHBC) is authorised by the Prudential Regulation Authority and regulated by the Financial Conduct Authority and the Prudential Regulation Authority for carrying on insurance business and insurance distribution activities.

NHBC is registered in England and Wales under company number 00320784. NHBC's registered address is NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Buckinghamshire, MK5 8FP. Note that only certain parts of our products and services are within the scope of UK financial services regulations. For more information on our products and services, please see our website [nhbc.co.uk](http://nhbc.co.uk) or your NHBC product documentation.

HB2851 07/24 W358ba