

# Disconnection of built-in kitchen appliances

(Withdrawn – January 2024)

The Technical Guidance Notes are produced by NHBC as guidance solely for our builder customers as to how to interpret the technical requirements in relation to the warranty cover provided by NHBC under its Buildmark, Buildmark Choice, Buildmark Link, Buildmark Solo, Buildmark Connect or any similar product from time to time. It has not been created or intended for distribution or use outside of that purpose. The information contained in this Technical Guidance Note does not constitute advice and is not to be relied upon by any third party. Nothing in this Technical Guidance Note is intended to, nor should it be taken to, create any legal or contractual relationship. Any third party who chooses to rely upon the information contained in the Technical Guidance Notes shall do so entirely at their own risk and NHBC accepts no duty of care or liability, however caused, in connection with its use or reliance by any third party.

## Question

Is it acceptable to locate the means of disconnection for a built-in kitchen appliance within the kitchen base unit housing that appliance?

## Considerations

- A built-in appliance should be capable of being disconnected before carrying out maintenance and repair. Removal of the appliance from its housing may not be necessary when carrying out such work. Means of disconnection located within the housing may therefore be difficult to access and operate.
- BS 7671 'Requirements for electrical installations. IET Wiring Regulations' does not specifically require the provision of a local means of disconnection to be provided for appliances.
- Many manufacturers of built-in appliances recommend that a means of disconnecting the appliance should be accessible when the product is installed.

## Answer

Best practice should be adopted when providing a means of electrical disconnection for built-in kitchen appliances i.e.

- Such means of disconnection should not require the removal of the appliance from its housing to access and operate.
- Disconnection should be local to the appliance to enable that appliance to be isolated without affecting the use of other electrical appliances or equipment on the same circuit.
- Such isolation should be reasonably accessible and in compliance with the appliance manufacturer's recommendations where provided.



**NHBC, NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Bucks MK5 8FP**  
**Tel: 0344 633 1000 Web: nhbc.co.uk**

National House-Building Council (NHBC) is authorised by the Prudential Regulation Authority and regulated by the Financial Conduct Authority and the Prudential Regulation Authority for carrying on insurance business and insurance distribution activities.

NHBC is registered in England and Wales under company number 00320784. NHBC's registered address is NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Buckinghamshire, MK5 8FP. Note that only certain parts of our products and services are within the scope of UK financial services regulations. For more information on our products and services, please see our website [nhbc.co.uk](http://nhbc.co.uk) or your NHBC product documentation.