## Fibre reinforced screeds

(Withdrawn - January 2024)

The Technical Guidance Notes are produced by NHBC as guidance solely for our builder customers as to how to interpret the technical requirements in relation to the warranty cover provided by NHBC under its Buildmark, Buildmark Choice, Buildmark Link, Buildmark Solo, Buildmark Connect or any similar product from time to time. It has not been created or intended for distribution or use outside of that purpose. The information contained in this Technical Guidance Note does not constitute advice and is not to be relied upon by any third party. Nothing in this Technical Guidance Note is intended to, nor should it be taken to, create any legal or contractual relationship. Any third party who chooses to rely upon the information contained in the Technical Guidance Notes shall do so entirely at their own risk and NHBC accepts no duty of care or liability, however caused, in connection with its use or reliance by any third party.

## Question

Can fibre reinforced floor screeds be used in place of wire mesh reinforced screeds when used over resilient insulation materials?

## **Considerations**

- NHBC Standards clauses 8.3 D3(j) and 8.3 S2(g) refer to the use of wire mesh reinforcement in cement : sand screeds over resilient insulation materials.
- Reinforcement is required to control drying shrinkage in the screed by transferring shrinkage to the edges of the floor to avoid cracking within the floor area.

## **Answer**

Fibre reinforced cement: sand screeds may be used in place of wire reinforced screeds over resilient slabs or quilts. The fibres should have independent assessment for use in the control of shrinkage in screeds or concrete.



NHBC, NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Bucks MK5 8FP Tel: 0344 633 1000 Web: nhbc.co.uk